



KING COUNTY

1200 King County Courthouse
516 Third Avenue
Seattle, WA 98104

Signature Report

April 24, 2006

Ordinance 15425

Proposed No. 2006-0167.1

Sponsors Ferguson

1 AN ORDINANCE making a supplemental appropriation
2 of \$3,960,000 of capital funds to provide the appropriate
3 level of appropriation authority on an emergency basis for
4 the Barton force main repair project in the conveyance
5 pipelines appropriation project category; and amending
6 the 2006 Budget Ordinance, Ordinance 15333, Section
7 116, as amended, and Attachment D, as amended.

8

9

10 BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

11 **SECTION 1. Findings.**

12 A. There is an emergency due to the failed section of the Beach Drive interceptor
13 at Lincoln park in West Seattle that is leaking sewage onto Lincoln Park beach and into
14 the Puget Sound.

15 B. On February 4, 2006, a section of the Beach Drive interceptor at Lincoln park
16 in West Seattle failed causing sewage to leak onto the Lincoln park beach and into Puget
17 Sound.

18 C. This was the second failure in less than one month, the first having occurred
19 on January 17, 2006, and having been repaired on January 21, 2006.

20 D. Immediately after the February 4 failure, the wastewater treatment
21 division ("WTD") of the department of natural resources and parks instituted tanker
22 trucking operations to move sewage from the Barton pump station to the Murray pump
23 station in order to reduce overflow sewage from entering Puget Sound. As the tanker
24 trucking operations were only partially effective in that there was still an overflow of
25 approximately one million gallons of sewage per day, six hundred feet out into Puget
26 Sound, a temporary pump station was installed and a temporary line was laid along the
27 beach to control sewage overflows.

28 E. Video inspection of the Beach interceptor after the February 4 failure revealed
29 four other sections of the interceptor that are at imminent risk of failure. WTD has
30 determined that further repair and use of the Beach Drive interceptor pipe at Lincoln park
31 is not feasible and that the thirty-inch concrete cylinder force main should be replaced
32 with two parallel twenty-four-inch diameter high density polyethylene pipes, one being
33 inserted into the failed pipe and one being laid parallel to it.

34 F. The second failure of the Beach Drive interceptor and the imminent risk of
35 failure of four additional sections of the interceptor and the resulting possibility of the
36 release of overflow sewage onto Lincoln park beach and into Puget Sound, constitute an
37 emergency situation that presents a real and immediate threat to public health, safety and
38 welfare.

39 G. Pursuant to K.C.C. 4.16.050, on February 17, 2006, the King County
40 executive issued a determination of emergency and waiver from procurement

41 requirements to repair a failed section of the Beach Drive interceptor at Lincoln park in
42 West Seattle that is leaking sewage onto Lincoln park beach and into the Puget Sound, to
43 protect public health, safety, welfare and property and the environment.

44 SECTION 2. Ordinance 15333 Section 116, as amended, is hereby amended by
45 adding thereto and inserting therein the following:

46 The Barton Force Main Repair Project 423XXX, in appropriation project category
47 A20500 Conveyance Pump Stations requires an appropriation of \$3,960,000 to cover all
48 costs and expenses associated with the design, construction and completion of the
49 emergency restoration.

50	<u>Fund</u>	<u>Capital Fund</u>	<u>Amount</u>
51	4616	Wastewater Treatment Capital	\$3,960,000

52 SECTION 3. Attachment A to this ordinance hereby amends Attachment D to


Ordinance 15425

53 Ordinance 15333, as amended, by adding thereto and inserting therein the projects listed
54 in Attachment A to this ordinance.
55


Ordinance 15425 was introduced on 4/10/2006 and passed by the Metropolitan King County Council on 4/24/2006, by the following vote:

Yes: 8 - Mr. Phillips, Mr. von Reichbauer, Ms. Lambert, Mr. Dunn, Mr. Gossett, Ms. Hague, Ms. Patterson and Mr. Constantine
No: 0
Excused: 1 - Mr. Ferguson


KING COUNTY COUNCIL
KING COUNTY, WASHINGTON


Larry Phillips, Chair

ATTEST:


Anne Noris, Clerk of the Council

APPROVED this 3 day of May, 2006.


Ron Sims, County Executive

RECEIVED
2006 MAY -3 PM 4:12
CLERK
KING COUNTY COUNCIL

Attachments A. Adopted Ordinance 15333, Section 116: Wastewater Treatment Capital Improvement Program

